



Slipstop Sydney Pty Ltd

Unit5,5 Clerke Place,
KURNELL NSW 2231

TEL. (02) 9668 8047
FAX. (02) 9668 8206

Email: jose@slipstop.com.au
Web: www.slipstop.com.au

Further to the completion of the indicative testing at Macquarie Renders – Sydney.
Summary report as follow:

Wet Slip Resistance Measurement of New Pedestrian Surfaces: AS 4586-2013 New Indicative Appendix A Table 2

- Microcement resine and sealer Mercadier (White): **P4 - SRV: 52**
- Microcement resine and sealer Mercadier (Grey): **P4 - SRV: 48**

A handwritten signature in black ink, appearing to be "Jose Rodriguez".

Jose Rodriguez

**Slipstop Sydney
5/5 Clerke Place
Kurnell NSW 2231**

E. jose@slipstop.com.au